



INSTALLATION CLEARANCES:

- 1) THIS APPLIANCE MAY BE INSTALLED ON COMBUSTIBLE FLOORING
- 2) MINIMUM CLEARANCES TO ADJACENT CONSTRUCTION ARE AS FOLLOWS:
 - LEFT & RIGHT SIDES: 24"
 - FRONT: 24"
 - REAR: 24"
 - CEILING HEIGHT: 100"

NOTES:

1. ALL DIMENSIONS SHOWN ARE IN INCHES (CENTIMETERS).
2. WHEN USING THE CONDENSATE NEUTRALIZER TANK, FOR PROPER CONDENSATE DRAINAGE, THE NEUTRALIZER TANK MUST BE INSTALLED IN A PIT OR THE HEATER AND THE CONDENSATE TRAP MUST BE ELEVATED 4" OR HIGHER ABOVE THE FLOOR. SEE CONDENSATE TANK INSTRUCTIONS OMM-0153 FOR DETAILS.
3. CLEARANCE DIMENSIONS ARE MINIMUMS RECOMMENDED BY PVI. LOCAL CODES AND AUTHORITIES SHOULD BE CONSULTED.



PVI INDUSTRIES
FORT WORTH, TEXAS

CENTURION GAS FIRED WATER HEATER
SINGLE & ZERO SIDE CLEARANCE UNITS
DIMENSIONAL DRAWING

DWN.BY K.S. DATE 080122
SCALE _____ SIZE A
CHKD. _____ APPD. _____
REV.DATE _____

SD-P-1240

REV.
A